



Matt Blunt, Governor • Doyle Childers, Director

## DEPARTMENT OF NATURAL RESOURCES

[www.dnr.mo.gov](http://www.dnr.mo.gov)

December 4, 2008

Mr. Stanley A. Walker, Chief  
Storage Tanks and Oil Pollution Branch  
U.S. Environmental Protection Agency  
901 North 5<sup>th</sup> Street  
Kansas City, KS 66101

Dear Mr. Walker:

Subsection (c) of Section 1526 of the Energy Policy Act amends Section 9002 in Subtitle I of the Solid Waste Disposal Act to add requirements for states to maintain, update, and make available to the public a record of underground storage tanks (USTs) regulated under Subtitle I. The Environmental Protection Agency (EPA) must require each state that receives funding under Subtitle I to meet the public record requirements. Subsection (d) of Section 9002 in Subtitle I requires EPA to prescribe the manner and form of the public record, and says that, to the maximum extent practicable, the public record of a state must include:

1. The number, sources, and causes of underground storage tank releases in the state
2. The record of compliance by USTs in the state with Subtitle I or a state program approved under Section 9004 of Subtitle I
3. Data on the number of UST equipment failures in the state

Enclosed is the Missouri Department of Natural Resources, Tanks Section, Annual Public Record Report for the period of October 1, 2007, through September 30, 2008. The department has placed this report on the Tanks Section web site at <http://www.dnr.mo.gov/env/hwp/tanks/tanks.htm>. A link to the report is located under the Quick Links. For your convenience, I have also provided the web address for the report, <http://www.dnr.mo.gov/env/hwp/docs/epareport12.3.08.pdf>. This report will also be made available by request to those that do not have internet access.

The first section of the report describes the number of UST facilities, individual regulated tanks, compliance rates in the State of Missouri, and an individual breakdown of the sources and causes of releases opened in Federal Fiscal Year 2008. The summary of sources and causes and the listing of sources and causes includes the listing of four releases from above ground storage

Mr. Stanley A. Walker, Chief  
Storage Tanks and Oil Pollution Branch  
U.S. Environmental Protection Agency  
Page Two

tanks (ASTs). These AST releases are regulated and the cleanup oversight is done by the department.

If you have any questions in this matter, please contact me at (573) 526-2058.

Sincerely,

HAZARDOUS WASTE PROGRAM



Ken Koon, Chief  
Tanks Section

KK:sr

Enclosure

c: Ms. Carol Eighmey, Petroleum Storage Tank Insurance Fund  
Ms. Kathy Flippin, Chief, Compliance/Enforcement Section  
Mr. Robert Geller, Director, Hazardous Waste Program  
Mr. Daniel R. Schuette, Director, Division of Environmental Quality



## Tanks Section Summary Information

### General Information

\*Based on data as of 11-30-08.

Total Number of Active UST Sites 3,706  
Total Number of Active USTs 9,854

Public Record Posted Date: 12/3/2008

### Summary Information for Inspections

\*As reported on Year End Report- based on information input as of 10-08-2008.

Inspection Period Dates were from 10/1/2007 to 9/30/2008  
Number of UST Facilities Inspected 821  
Percent Compliance\* 87.46%

\*Percentage of UST Facilities in Significant Operational Compliance with the UST Release Detection and Release Prevention (spill, overfill, and corrosion) Requirements

### Summary Information for Releases

\*Based on data as of 11-30-08.

Number of UST Remediation Cases Opened 90  
Remediation Case Dates Added were from 10/1/2007 to 9/30/2008

### Summary Information for Release Sources and Causes

Source	Cause															
	Spill		Overfill		Phys/Mech Damage		Corrosion		Install Problem		Other		Unknown			
	#	%	#	%	#	%	#	%	#	%	#	%	#	%		
Tank	2	2.22%			1	1.11%									1	1.11%
Piping	7	7.78%						1	1.11%	1	1.11%				5	5.56%
Dispenser	-	-														
STP	-	-														
Delivery Problem	-	-														
Other	-	-														
Unknown	81	90.00%													81	90.00%
<b>Totals</b>	<b>90</b>	<b>-</b>	<b>0</b>	<b>-</b>	<b>1</b>	<b>1.11%</b>	<b>0</b>	<b>-</b>	<b>1</b>	<b>1.11%</b>	<b>1</b>	<b>1.11%</b>	<b>0</b>	<b>-</b>	<b>87</b>	<b>96.67%</b>

\*Aboveground Storage Tank data was not included in this breakdown.